



# Horsham New wastewater system: map and key facts



Population Equivalent (PE)	66,861
Discharge Waterbody	Arun Horsham
Number of Pumping Stations	53
Number of Overflows	3
Length of Sewer (km)	617.8
Catchment Reference	HONE

BRAVA Results Table		
Planning Objective	2020	2050
1 Internal Sewer Flooding Risk	0	
2 Pollution Risk	1	
3 Sewer Collapse Risk	0	
4 Risk of Sewer Flooding in a 1 in 50 year storm	2	2
5 Storm Overflow performance	1	1
6 Risk of WTW Compliance Failure	1	1
7 Risk of flooding due to Hydraulic Overload	1	2
8 Dry Weather Flow Compliance	0	0
9 Good Ecological Status / Potential	1	
10 Surface Water Management	2	
11 Nutrient Neutrality	2	2
12 Groundwater Pollution	0	
13 Bathing Waters	NA	
14 Shellfish Waters	NA	